

Schena, Cristeen

From: Aram Varjabedian <avarjabedian@woodardcurran.com>
Sent: Tuesday, March 06, 2018 6:06 PM
To: tberardinelli@town.hull.ma.us; Bill Boornazian; david.burns (david.burns@state.ma.us); Jim Dow; Frank Cavaleri; jstruzziery@town.hull.ma.us; jsullivan (jsullivan@town.hull.ma.us); Kate Roosa; kbornheim (kbornheim@town.hull.ma.us); Krahforst, Chris (ckrahforst@town.hull.ma.us); Lemnios, Philip (plemnios@town.hull.ma.us); coconnor@town.hull.ma.us; Robert Scott; Turin, David
Subject: RE: Hull, MA - MA0101231 - SSO Notification - near 83 Main Street, Hull, MA resend

Good evening:

Please disregard first email which had info from an earlier SSO. I apologize for the oversight. It has been a long week.

On March 5th at approximately 5pm we investigated a call on a leak in the road on Main Street near #83. The main line manholes upstream and downstream of this location were found to be flowing satisfactorily. Upon checking a clean out by the side of the road where the leak was seen, we verified that this leak was sanitary sewage. This was residential flow from one house and the line was snaked and the blockage cleared earlier this morning.

A full SSO report will follow.

Sincerely,

Aram

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue | Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS